

**INTERGAS**

Švari energija Jums!

2017 M. SAUSIO MĖNESIO**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2017-02-02

Mažeikiai

2017 m. sausio mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,8627	11,0474	1,0738
2	11,8581	11,0431	1,0738
3	11,8274	11,0145	1,0738
4	11,8088	10,9972	1,0738
5	11,8148	11,0028	1,0738
6	11,8419	11,0280	1,0738
7	11,8464	11,0322	1,0738
8	11,8574	11,0425	1,0738
9	11,8394	11,0257	1,0738
10	11,8506	11,0361	1,0738
11	11,8539	11,0392	1,0738
12	11,8471	11,0329	1,0738
13	11,8476	11,0333	1,0738
14	11,7053	10,9008	1,0738
15	11,4612	10,6735	1,0738
16	11,2106	10,4401	1,0738
17	11,3224	10,5442	1,0738
18	11,4684	10,6802	1,0738
19	11,4320	10,6463	1,0738
20	11,4979	10,7077	1,0738
21	11,5046	10,7139	1,0738
22	11,5180	10,7264	1,0738
23	11,5364	10,7435	1,0738
24	11,5352	10,7424	1,0738
25	11,5991	10,8019	1,0738
26	11,5374	10,7445	1,0738
27	11,5394	10,7463	1,0738
28	11,5167	10,7252	1,0738
29	11,2686	10,4941	1,0738
30	11,3073	10,5302	1,0738
31	11,1980	10,4284	1,0738
Vidurkis	11,6166	10,8182	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.