

**INTERGAS**

2022 M. GEGUŽĖS MĖNESIO

GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE

2022-06-03

Mažeikiai

2022 m. gegužės mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,2696	10,4951	1,0738
2	11,2682	10,4938	1,0738
3	11,271	10,4964	1,0738
4	11,2725	10,4978	1,0738
5	11,2671	10,4927	1,0738
6	11,2725	10,4978	1,0738
7	11,2779	10,5028	1,0738
8	11,1968	10,4273	1,0738
9	11,1926	10,4234	1,0738
10	11,1967	10,4272	1,0738
11	11,203	10,4330	1,0738
12	11,2103	10,4398	1,0738
13	11,2167	10,4458	1,0738
14	11,2203	10,4492	1,0738
15	11,2229	10,4516	1,0738
16	11,2163	10,4454	1,0738
17	11,2221	10,4508	1,0738
18	11,2884	10,5126	1,0738
19	11,4005	10,6170	1,0738
20	11,4101	10,6259	1,0738
21	11,3984	10,6150	1,0738
22	11,4002	10,6167	1,0738
23	11,4103	10,6261	1,0738
24	11,4124	10,6280	1,0738
25	11,4109	10,6267	1,0738
26	11,4112	10,6269	1,0738
27	11,4124	10,6280	1,0738
28	11,3264	10,5480	1,0738
29	11,2701	10,4955	1,0738
30	11,2462	10,4733	1,0738
31	11,2467	10,4737	1,0738
Vidurkis	11,2916	10,5156	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.