



INTERGAS
Švari energija. Jums!

**2024 M. BALANDŽIO MĖNESIO
GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2024-05-03
Mažeikiai

| 2024 m. balandžio mėn. | Viršutinis šilumingumas kWh/m ³ | | Perskaičiavimo koeficientas |
|------------------------------|--|----------------|--------------------------------|
| | 0 C° matavimo | 20 C° matavimo | |
| 1 | 11.7953 | 10.9846 | 1.0738 |
| 2 | 11.8024 | 10.9912 | 1.0738 |
| 3 | 11.8113 | 10.9995 | 1.0738 |
| 4 | 11.8221 | 11.0096 | 1.0738 |
| 5 | 11.8249 | 11.0122 | 1.0738 |
| 6 | 11.7803 | 10.9707 | 1.0738 |
| 7 | 11.7925 | 10.9820 | 1.0738 |
| 8 | 11.8029 | 10.9917 | 1.0738 |
| 9 | 11.8085 | 10.9969 | 1.0738 |
| 10 | 11.8076 | 10.9961 | 1.0738 |
| 11 | 11.8095 | 10.9979 | 1.0738 |
| 12 | 11.8207 | 11.0083 | 1.0738 |
| 13 | 11.8259 | 11.0131 | 1.0738 |
| 14 | 11.8325 | 11.0193 | 1.0738 |
| 15 | 11.6992 | 10.8951 | 1.0738 |
| 16 | 11.2981 | 10.5216 | 1.0738 |
| 17 | 11.3020 | 10.5252 | 1.0738 |
| 18 | 11.3122 | 10.5347 | 1.0738 |
| 19 | 11.3187 | 10.5408 | 1.0738 |
| 20 | 11.5112 | 10.7201 | 1.0738 |
| 21 | 11.7817 | 10.9720 | 1.0738 |
| 22 | 11.7679 | 10.9591 | 1.0738 |
| 23 | 11.7676 | 10.9588 | 1.0738 |
| 24 | 11.7793 | 10.9697 | 1.0738 |
| 25 | 11.7879 | 10.9777 | 1.0738 |
| 26 | 11.8006 | 10.9896 | 1.0738 |
| 27 | 11.8067 | 10.9953 | 1.0738 |
| 28 | 11.8112 | 10.9994 | 1.0738 |
| 29 | 11.7237 | 10.9180 | 1.0738 |
| 30 | 11.7458 | 10.9385 | 1.0738 |
| Vidurkis | 11.7183 | 10.9130 | - |

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.