

**INTERGAS**

Švari energija. Jums!

**2024 M. SPALIO MĖNESIO****GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2024-11-03

Mažeikiai

2024 m. spalio mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11.3236	10.5454	1.0738
2	11.5114	10.7202	1.0738
3	11.5728	10.7774	1.0738
4	11.5858	10.7895	1.0738
5	11.5952	10.7983	1.0738
6	11.6022	10.8048	1.0738
7	11.6016	10.8042	1.0738
8	11.5996	10.8024	1.0738
9	11.6041	10.8066	1.0738
10	11.6020	10.8046	1.0738
11	11.6025	10.8051	1.0738
12	11.6197	10.8211	1.0738
13	11.6153	10.8170	1.0738
14	11.6197	10.8211	1.0738
15	11.4320	10.6463	1.0738
16	11.3336	10.5547	1.0738
17	11.3376	10.5584	1.0738
18	11.3414	10.5619	1.0738
19	11.3460	10.5662	1.0738
20	11.3488	10.5688	1.0738
21	11.3536	10.5733	1.0738
22	11.5815	10.7855	1.0738
23	11.8056	10.9942	1.0738
24	11.8255	11.0128	1.0738
25	11.8340	11.0207	1.0738
26	11.8484	11.0341	1.0738
27	11.8632	11.0479	1.0738
28	11.8427	11.0288	1.0738
29	11.8313	11.0182	1.0738
30	11.6856	10.8825	1.0738
31	11.4195	10.6347	1.0738
<b>Viđurkis</b>	<b>11.5834</b>	<b>10.7873</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.