

**INTERGAS**

Švari energija. Jums!

**2020 M. LIEPOS MĖNESIO****GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2020-08-03

Mažeikiai

2020 m. liepos mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,4541	10,6669	1,0738
2	11,458	10,6705	1,0738
3	11,3823	10,6000	1,0738
4	11,3696	10,5882	1,0738
5	11,4908	10,7011	1,0738
6	11,7302	10,9240	1,0738
7	11,7861	10,9761	1,0738
8	11,7907	10,9804	1,0738
9	11,7966	10,9858	1,0738
10	11,6304	10,8311	1,0738
11	11,6677	10,8658	1,0738
12	11,8058	10,9944	1,0738
13	11,8117	10,9999	1,0738
14	11,6427	10,8425	1,0738
15	11,6064	10,8087	1,0738
16	11,8218	11,0093	1,0738
17	11,8233	11,0107	1,0738
18	11,8317	11,0185	1,0738
19	11,7263	10,9204	1,0738
20	11,5573	10,7630	1,0738
21	11,7357	10,9291	1,0738
22	11,7573	10,9492	1,0738
23	11,7751	10,9658	1,0738
24	11,7714	10,9624	1,0738
25	11,7663	10,9576	1,0738
26	11,5411	10,7479	1,0738
27	11,5946	10,7977	1,0738
28	11,7948	10,9842	1,0738
29	11,7964	10,9857	1,0738
30	11,7704	10,9614	1,0738
31	11,7355	10,9289	1,0738
<b>Vidurkis</b>	<b>11,6846</b>	<b>10,8815</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiam slėgiui bei esant sausoms dujoms.