



**INTERGAS** 2019 M. SPALIO MĖNESIO

**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2019-11-05

Mažeikiai

2019 m. spalio mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,8118	11,0000	1,0738
2	11,7852	10,9752	1,0738
3	11,7874	10,9773	1,0738
4	11,7872	10,9771	1,0738
5	11,7861	10,9761	1,0738
6	11,7882	10,9780	1,0738
7	11,8164	11,0043	1,0738
8	11,8109	10,9992	1,0738
9	11,8275	11,0146	1,0738
10	11,7926	10,9821	1,0738
11	11,7960	10,9853	1,0738
12	11,8453	11,0312	1,0738
13	11,8391	11,0254	1,0738
14	11,8468	11,0326	1,0738
15	11,8705	11,0547	1,0738
16	11,8482	11,0339	1,0738
17	11,6283	10,8291	1,0738
18	11,7323	10,9260	1,0738
19	11,8677	11,0521	1,0738
20	11,8632	11,0479	1,0738
21	11,6110	10,8130	1,0738
22	11,7891	10,9789	1,0738
23	11,8526	11,0380	1,0738
24	11,8290	11,0160	1,0738
25	11,8167	11,0046	1,0738
26	11,8037	10,9925	1,0738
27	11,8424	11,0285	1,0738
28	11,6776	10,8750	1,0738
29	11,7540	10,9462	1,0738
30	11,5577	10,7634	1,0738
31	11,7546	10,9467	1,0738
<b>Vidurkis</b>	<b>11,7877</b>	<b>10,9776</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.