

**INTERGAS**

Švari energija. Jums.

2020 M. SPALIO MĖNESIO**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2020-11-04

Mažeikiai

2020 m. spalio mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,6538	10,8529	1,0738
2	11,3608	10,5800	1,0738
3	11,7918	10,9814	1,0738
4	11,8192	11,0069	1,0738
5	11,8101	10,9984	1,0738
6	11,8249	11,0122	1,0738
7	11,7717	10,9627	1,0738
8	11,3851	10,6026	1,0738
9	11,3497	10,5697	1,0738
10	11,3505	10,5704	1,0738
11	11,3109	10,5335	1,0738
12	11,2977	10,5212	1,0738
13	11,3012	10,5245	1,0738
14	11,3112	10,5338	1,0738
15	11,3149	10,5373	1,0738
16	11,319	10,5411	1,0738
17	11,3133	10,5358	1,0738
18	11,3159	10,5382	1,0738
19	11,3204	10,5424	1,0738
20	11,3177	10,5399	1,0738
21	11,3133	10,5358	1,0738
22	11,3181	10,5402	1,0738
23	11,3203	10,5423	1,0738
24	11,3214	10,5433	1,0738
25	11,3238	10,5455	1,0738
26	11,3273	10,5488	1,0738
27	11,3292	10,5506	1,0738
28	11,3279	10,5494	1,0738
29	11,3365	10,5574	1,0738
30	11,3418	10,5623	1,0738
31	11,3467	10,5669	1,0738
Vidurkis	11,4144	10,6299	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.