

**INTERGAS**

Švari energija. Jums!

2021 M. KOVO MĖNESIO**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2021-04-01

Mažeikiai

2021 m. kovo mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,2899	10,5140	1,0738
2	11,293	10,5169	1,0738
3	11,2968	10,5204	1,0738
4	11,2999	10,5233	1,0738
5	11,3056	10,5286	1,0738
6	11,3246	10,5463	1,0738
7	11,3046	10,5277	1,0738
8	11,2896	10,5137	1,0738
9	11,2816	10,5062	1,0738
10	11,2888	10,5129	1,0738
11	11,2952	10,5189	1,0738
12	11,3153	10,5376	1,0738
13	11,3212	10,5431	1,0738
14	11,3233	10,5451	1,0738
15	11,3404	10,5610	1,0738
16	11,3482	10,5683	1,0738
17	11,3486	10,5686	1,0738
18	11,3496	10,5696	1,0738
19	11,3542	10,5738	1,0738
20	11,3553	10,5749	1,0738
21	11,3563	10,5758	1,0738
22	11,3572	10,5766	1,0738
23	11,3593	10,5786	1,0738
24	11,3559	10,5754	1,0738
25	11,3556	10,5752	1,0738
26	11,3573	10,5767	1,0738
27	11,3617	10,5808	1,0738
28	11,3528	10,5725	1,0738
29	11,4293	10,6438	1,0738
30	11,4278	10,6424	1,0738
31	11,3725	10,5909	1,0738
Vidurkis	11,3359	10,5568	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.