

**INTERGAS**

Švari energija. Jums!

2020 M. VASARIO MĖNESIO

GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE

2020-03-04

Mažeikiai

2020 m. vasario mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,6275	10,8284	1,0738
2	11,8345	11,0211	1,0738
3	11,8526	11,0380	1,0738
4	11,5053	10,7146	1,0738
5	11,8179	11,0057	1,0738
6	11,8528	11,0382	1,0738
7	11,7126	10,9076	1,0738
8	11,8348	11,0214	1,0738
9	11,7875	10,9774	1,0738
10	11,7425	10,9355	1,0738
11	11,3708	10,5893	1,0738
12	11,7814	10,9717	1,0738
13	11,8013	10,9902	1,0738
14	11,7857	10,9757	1,0738
15	11,8036	10,9924	1,0738
16	11,7285	10,9224	1,0738
17	11,5383	10,7453	1,0738
18	11,8337	11,0204	1,0738
19	11,8208	11,0084	1,0738
20	11,8080	10,9965	1,0738
21	11,8159	11,0038	1,0738
22	11,8171	11,0049	1,0738
23	11,8228	11,0102	1,0738
24	11,8215	11,0090	1,0738
25	11,7983	10,9874	1,0738
26	11,8000	10,9890	1,0738
27	11,7796	10,9700	1,0738
28	11,7791	10,9695	1,0738
29	11,7970	10,9862	1,0738
Vidurkis	11,7611	10,9528	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.

