

**INTERGAS**

Šviri energija Jums!

2018 M. BALANDŽIO MĖNESIO**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2018-05-03

Mažeikiai

2018 m. balandžio mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,8407	11,0269	1,0738
2	11,8574	11,0425	1,0738
3	11,8838	11,0671	1,0738
4	11,8664	11,0508	1,0738
5	11,6759	10,8734	1,0738
6	11,8574	11,0425	1,0738
7	11,9402	11,1196	1,0738
8	11,8611	11,0459	1,0738
9	11,8409	11,0271	1,0738
10	11,8352	11,0218	1,0738
11	11,8457	11,0316	1,0738
12	11,8621	11,0468	1,0738
13	11,8837	11,0670	1,0738
14	11,8556	11,0408	1,0738
15	11,8571	11,0422	1,0738
16	11,7785	10,9690	1,0738
17	11,7567	10,9487	1,0738
18	11,8530	11,0384	1,0738
19	11,8576	11,0427	1,0738
20	11,8654	11,0499	1,0738
21	11,8659	11,0504	1,0738
22	11,8664	11,0508	1,0738
23	11,8659	11,0504	1,0738
24	11,8653	11,0498	1,0738
25	11,8646	11,0492	1,0738
26	11,7931	10,9826	1,0738
27	11,8418	11,0279	1,0738
28	11,8606	11,0454	1,0738
29	11,8625	11,0472	1,0738
30	11,8651	11,0496	1,0738
Vidurkis	11,8475	11,0333	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiui slėgiui bei esant sausoms dujoms.