

2022 m. liepos mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,3773	10,5954	1,0738
2	11,7256	10,9197	1,0738
3	11,7289	10,9228	1,0738
4	11,736	10,9294	1,0738
5	11,7466	10,9393	1,0738
6	11,7495	10,9420	1,0738
7	11,7593	10,9511	1,0738
8	11,7745	10,9653	1,0738
9	11,7994	10,9885	1,0738
10	11,8148	11,0028	1,0738
11	11,4579	10,6704	1,0738
12	11,4481	10,6613	1,0738
13	11,4519	10,6648	1,0738
14	11,4557	10,6684	1,0738
15	11,4578	10,6703	1,0738
16	11,4577	10,6702	1,0738
17	11,4701	10,6818	1,0738
18	11,4717	10,6833	1,0738
19	11,4688	10,6806	1,0738
20	11,4323	10,6466	1,0738
21	11,4333	10,6475	1,0738
22	11,4352	10,6493	1,0738
23	11,4384	10,6523	1,0738
24	11,4421	10,6557	1,0738
25	11,4424	10,6560	1,0738
26	11,446	10,6593	1,0738
27	11,4505	10,6635	1,0738
28	11,4319	10,6462	1,0738
29	11,3625	10,5816	1,0738
30	11,3602	10,5794	1,0738
31	11,3989	10,6155	1,0738
<b>Vidurkis</b>	<b>11,5298</b>	<b>10,7374</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20 °C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.