

**INTERGAS**

Švari energija Jums!

2022 M. RUGPJŪČIO MĖNESIO

**GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2022-09-03

Mažeikiai

2022 m. rugpjūčio mėn.	Viršutinis šilumingumas kWh/m <sup>3</sup>		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,3653	10,5842	1,0738
2	11,3666	10,5854	1,0738
3	11,3644	10,5833	1,0738
4	11,3641	10,5831	1,0738
5	11,3457	10,5659	1,0738
6	11,381	10,5988	1,0738
7	11,3651	10,5840	1,0738
8	11,3694	10,5880	1,0738
9	11,3716	10,5901	1,0738
10	11,3689	10,5875	1,0738
11	11,5724	10,7771	1,0738
12	11,7289	10,9228	1,0738
13	11,7475	10,9401	1,0738
14	11,4573	10,6699	1,0738
15	11,3694	10,5880	1,0738
16	11,3737	10,5920	1,0738
17	11,3748	10,5930	1,0738
18	11,3767	10,5948	1,0738
19	11,3792	10,5971	1,0738
20	11,382	10,5997	1,0738
21	11,3834	10,6010	1,0738
22	11,3892	10,6064	1,0738
23	11,6564	10,8553	1,0738
24	11,7312	10,9249	1,0738
25	11,7451	10,9379	1,0738
26	11,7627	10,9543	1,0738
27	11,5678	10,7728	1,0738
28	11,4995	10,7092	1,0738
29	11,6103	10,8123	1,0738
30	11,4274	10,6420	1,0738
31	11,4372	10,6511	1,0738
<b>Vidurkis</b>	<b>11,4721</b>	<b>10,6836</b>	-

\* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.