

**INTERGAS**

Švari energija Jums!

**2022 M. GRUODŽIO MĖNESIO
GAMTINIŲ DUJŲ VIRŠUTINIS ŠILUMINGUMAS MAŽEIKIŲ DUJŲ APSKAITOS STOTYJE**

2023-01-03

Mažeikiai

2022 m. gruodžio mėn.	Viršutinis šilumingumas kWh/m ³		Perskaičiavimo koeficientas
	0 C° matavimo	20 C° matavimo	
1	11,8062	10,9948	1,0738
2	11,8121	11,0003	1,0738
3	11,8177	11,0055	1,0738
4	11,8235	11,0109	1,0738
5	11,8303	11,0172	1,0738
6	11,8361	11,0226	1,0738
7	11,6450	10,8447	1,0738
8	11,5140	10,7227	1,0738
9	11,5133	10,7220	1,0738
10	11,5164	10,7249	1,0738
11	11,5166	10,7251	1,0738
12	11,5103	10,7192	1,0738
13	11,5165	10,7250	1,0738
14	11,5242	10,7322	1,0738
15	11,7100	10,9052	1,0738
16	11,8090	10,9974	1,0738
17	11,8130	11,0011	1,0738
18	11,8256	11,0129	1,0738
19	11,8363	11,0228	1,0738
20	11,8391	11,0254	1,0738
21	11,8427	11,0288	1,0738
22	11,8553	11,0405	1,0738
23	11,8707	11,0549	1,0738
24	11,7954	10,9847	1,0738
25	11,7436	10,9365	1,0738
26	11,7466	10,9393	1,0738
27	11,7495	10,9420	1,0738
28	11,7537	10,9459	1,0738
29	11,7625	10,9541	1,0738
30	11,7745	10,9653	1,0738
31	11,7688	10,9600	1,0738
Vidurkis	11,7316	10,9253	-

* Skirstymo sistemos operatoriaus viršutinio dujų šilumingumo vertės nurodytos esant norminėms sąlygoms: +25 °C degimo temperatūrai, +20°C matavimo temperatūrai ir 101,325 kPa absoliutiniam slėgiui bei esant sausoms dujoms.